




TECHNICAL SPECIFICATIONS
QUALITY LABORATORY
MODEL
45,6X45,6 LEITHA-H/5
BODY TYPE
PORCELAIN GROUP Bla

Body Technical Specifications		Test Method	Standard Value	Pass/Fail
 Length and width			± 0.6 %	Yes
			± 5 %	Yes
			± 0.5 %	Yes
			± 0.5 %	Yes
			± 0.5 %	
 Water absorption			<0.5 %	Yes
 Breaking strength			>1300 N	Yes
			>35 N/mm²	Yes
 Frost resistance			RESIST	Yes
 Linear thermal expansion coefficient			9*10^-6 K^-1	Yes

Surface Technical Specifications		Test Method	Standard Value	Pass/Fail
 Slipperiness		DIN-51130	R9	Yes
		UNE-ENV-12633	CLASS 1	Yes
 Surface abrasion resistance (PEI)			4	Yes
 Deep abrasion resistance			-	-
 Surface hardness (MOHS scale)		EN-101	6	Yes
 Acids and alkalis resistance			GLA/GLA	Yes
 Crazing resistance			RESIST	Yes
 Staining resistance			5	Yes
 Surface Quality			> 95 %	Yes

GOODS ARE IN CONFORMITY WITH ISO 13006 STANDARDS


 Avenida Manuel Escobedo, 26
 33002 Oviedo (Asturias) España
Head of Laboratory